

SISTERSVILLE MUNICIPAL WATER

WV3304803

Consumer Confidence Report – 2024

Covering Calendar Year – 2023

This brochure is a snapshot of the quality of the water that we provided last year. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. If you would like to observe the decision-making process that affects drinking water quality or if you have any questions, comments, or suggestions, please attend any regularly scheduled water board meeting held on the second Monday of each month at 7:00PM in the Municipal Building Conference room or call JASON W. RICE at 304-652-6361.

Our drinking water is supplied from another water system through a Consecutive Connection (CC). To find out more about our drinking water sources and additional chemical sampling results, please contact our office at the number provided above. Your water comes from Ground water:

Source Name	Source Water Type
CC FROM WV3304801 TYLER COUNTY PSD	Ground water

Buyer Name	Seller Name
WV3304803 - SISTERSVILLE MUNICIPAL WATER	TYLER COUNTY PSD

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) included rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in sources water before we treat it include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which may come from a variety of sources such as storm water run-off, agriculture, and residential users.

Radioactive contaminants, which can be naturally occurring or the result of mining activity.

Organic contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also come from gas stations, urban storm water run-off, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limits the amount of certain contaminants in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Our water system has an estimated population of 1892 and is required to test a minimum of 2 sample(s) per month in accordance with the Total Coliform Rule for microbiological contaminants. Coliform bacteria are usually harmless, but their presence in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public.

Water Quality Data

The following tables list all of the drinking water contaminants which were detected during the 2023 calendar year. The presence of these contaminants does not necessarily indicate the water poses a health risk. Unless noted, the data presented in this table is from the testing done January 1- December 31, 2023. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Terms & Abbreviations

Maximum Contaminant Level Goal (MCLG): the "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLGs allow for a margin of safety.

Maximum Contaminant Level (MCL): the "Maximum Allowed" is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Secondary Maximum Contaminant Level (SMCL): recommended level for a contaminant that is not regulated and has no MCL.

Action Level (AL): the concentration of a contaminant that, if exceeded, triggers treatment or other requirements.

Treatment Technique (TT): a required process intended to reduce levels of a contaminant in drinking water.

Maximum Residual Disinfectant Level (MRDL): the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Non-Detects (ND): lab analysis indicates that the contaminant is not present.

Parts per Million (ppm): or milligrams per liter (mg/L)

Parts per Billion (ppb): or micrograms per liter (µg/L)

Picocuries per Liter (pCi/L): a measure of the radioactivity in water.

Millirems per Year (mrem/yr): measure of radiation absorbed by the body.

Monitoring Period Average (MPA): An average of sample results obtained during a defined time frame, common examples of monitoring periods are monthly, quarterly and yearly.

Nephelometric Turbidity Unit (NTU): a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is not regulated for groundwater systems.

Running Annual Average (RAA): an average of sample results obtained over the most current 12 months and used to determine compliance with MCLs.

Locational Running Annual Average (LRAA): Average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

Testing Results for: SISTERSVILLE MUNICIPAL WATER

Regulated Contaminants	Collection Date	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
FLUORIDE	8/5/2021	0.62	0.44 - 0.62	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NITRATE	12/9/2020	0.76	0.76	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Collection Date	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	822 WELLS ST	2023	9	1 - 4	ppb	60	0	By-product of drinking water disinfection
TTHM	822 WELLS ST	2023	12	1 - 5	ppb	80	0	By-product of drinking water chlorination

Lead and Copper	Monitoring Period	90TH Percentile	Range (low/high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2023	0.737	0.0201 - 0.918	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2023	1.5	0.1 - 4.5	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

SISTERSVILLE MUNICIPAL WATER is working towards identifying service line materials throughout the water distribution supply. The service line inventory is required to be submitted to the state by October 16, 2024. The most up to date inventory is located at City Building, if you have any questions about our inventory, please contact JASON W. RICE at 304-652-6361.

Chlorine/Chloramines Maximum Disinfection Level	MPA	MPA Units	RAA	RAA Units
1/1/2023 - 1/31/2023	1.14000	MG/L	1.20000	MG/L

Unresolved Deficiency Date Identified	Facility	Comments
6/1/2018	TREATMENT PLANT	Sedimentation tanks require cleaning and properly secured. This deficiency has been listed in past reports

During the 2023 calendar year, we had the below noted violation(s) of drinking water regulations.

Compliance Period	Analyte	Comments
1/1/2021 - 12/31/2021	PUBLIC NOTICE	Failed to issue public notice or failed to provide a copy of the notice and certification to the state
10/1/2021 - 12/31/2021	PUBLIC NOTICE	Failed to issue public notice or failed to provide a copy of the notice and certification to the state
1/1/2022 - 3/31/2022	PUBLIC NOTICE	Failed to issue public notice or failed to provide a copy of the notice and certification to the state
7/1/2023 - 7/31/2023	CHLORINE	Failed to monitor/report as required for chlorine or disinfection by-products
9/1/2023 - 9/30/2023	E. COLI	Failed to collect routine or replacement coliform samples
9/1/2023 - 9/30/2023	CHLORINE	Failed to monitor/report as required for chlorine or disinfection by-products
9/1/2023 - 9/30/2023	CHLORINE	Failed to collect and/or report required surface water treatment monitoring

There are no additional required health effects notices.

There are no additional required health effects violation notices.

Some or all of our drinking water is supplied from another water system. The table below lists all of the drinking water contaminants, which were detected during the 2023 calendar year from the water systems that we purchase drinking water from.

Regulated Contaminants	Collection Date	Water System	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
ANTIMONY, TOTAL	9/20/2023	TYLER COUNTY PSD	0.503	0.503	ppb	6	6	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
ARSENIC	9/20/2023	TYLER COUNTY PSD	2.53	2.53	ppb	10	0	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
BARIUM	9/20/2023	TYLER COUNTY PSD	0.0602	0.0602	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
BERYLLIUM, TOTAL	9/20/2023	TYLER COUNTY PSD	0.503	0.503	ppb	4	4	Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries
CADMIUM	9/20/2023	TYLER COUNTY PSD	0.503	0.503	ppb	5	5	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; Runoff from waste batteries and paints
CHROMIUM	9/20/2023	TYLER COUNTY PSD	3.3	3.3	ppb	100	100	Discharge from steel and pulp mills; Erosion of natural deposits
CYANIDE	9/20/2023	TYLER COUNTY PSD	20.3	20.3	ppb	200	200	Discharge from steel/metal factories; Discharge from plastic and fertilizer factories
FLUORIDE	9/20/2023	TYLER COUNTY PSD	0.13	0.13	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
MERCURY	9/20/2023	TYLER COUNTY PSD	0.203	0.203	ppb	2	2	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland
NITRATE	4/6/2023	TYLER COUNTY PSD	1.9	1.9	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRATE-NITRITE	4/6/2023	TYLER COUNTY PSD	2.4	2.4	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRITE	4/6/2023	TYLER COUNTY PSD	0.503	0.503	ppm	1	1	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
SELENIUM	9/20/2023	TYLER COUNTY PSD	1.5	1.5	ppb	50	50	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
THALLIUM, TOTAL	9/20/2023	TYLER COUNTY PSD	0.503	0.503	ppb	2	0.5	Leaching from ore-processing sites; Discharge from electronics, glass, and drug factories

Secondary Contaminants.	Collection Date	Water System	Highest Value	Range (low/high)	Unit	SMCL
NICKEL	9/20/2023	TYLER COUNTY PSD	0.00253	0.00253	MG/L	0.1
SODIUM	9/20/2023	TYLER COUNTY PSD	17.9	17.9	MG/L	1000

Please Note: Because of sampling schedules, results may be older than 1 year.

During the 2023 calendar year, the water systems that we purchase water from had the below noted violation(s) of drinking water regulations.

Water System	Type	Category	Analyte	Compliance Period
WV3304801	CCR REPORT	RPT	CONSUMER CONFIDENCE RULE	7/1/2023
WV3304801	FAILURE TO COMPLETE OR SUBMIT MOR	MON	CHLORINE	11/1/2023 - 11/30/2023
WV3304801	MONITORING, ROUTINE (DBP), MAJOR	MON	CHLORINE	11/1/2023 - 11/30/2023

Your CCR is available at <http://www.cityofsistersville.com>

To receive a paper copy in the mail, please contact us at the phone number above.